

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE		PAGE OF PAGES 1/1		
2. AMENDMENT/MODIFICATION NO. RFQ_PR10539261-0001		3. EFFECTIVE DATE May 23, 2022		4. REQUISITION/PURCHASE REQ. NO. RFQ_PR10539261-0001		5. PROJECT NO. (If applicable)	
6. ISSUED BY Department of State American Embassy Bangkok of Thailand 120-122 Wireless Rd., Lumpini, Pathumwan, Bangkok 10330			CODE		7. ADMINISTERED BY (If other than Item 6) CODE		
8. NAME AND ADDRESS OF CONTRACTOR (NO., street,city,county,State,and ZIP Code)					9a. AMENDMENT OF SOLICITATION NO. RFQ_PR10539261-0001		
					9b. DATED (SEE ITEM 11)		
					10a. MODIFICATION OF CONTRACT/ORDER NO.		
					10b. DATED (SEE ITEM 13)		
<b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>							
<p>[ ] The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers [x] is extended, [ ] is not extended</p> <p>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment;(b) By acknowledging receipt of this amendment on each copy of the offer submitted; or(c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers.</p> <p><b>FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.</p>							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
<b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.</b>							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
X B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(b)							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor [ ] is not, [ ] is required to sign this document and return ____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)							
The purpose of this amendment is to extend bid due date from May 25 <sup>th</sup> 2022 to June 1 <sup>st</sup> 2022, before 16:00 hrs (Bangkok local time).							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME OF CONTRACTING OFFICER			
15B. NAME OF CONTRACTOR/OFFEROR  BY _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY <u>Scott Krushinski</u> (Signature of Contracting Officer)		16C. DATE SIGNED  05/23/2022	



**American Embassy Bangkok**  
GSO/Procurement and Contracting Office  
93/1 GPF Tower A, 5<sup>th</sup> Fl., Wireless Road  
Lumpini, Khet Pathumwan, Bangkok 10330

Solicitation No. PR10539261 – RAJ Flood pump replacement  
Questions and Answers  
May 23, 2022

Attention interested bidders:

Please see responses to bidders questions for the RAJ Flood pump replacement solicitation. Photos and AutoCAD drawings are available upon request. The deadline for submitting bids has been extended to June 1, 2022 at 16:00 hrs. Bangkok time.

**Q1:** Please provide information for the following:

Plan layout & Final Civil construction drawing only pump installation area, especially Civil/Foundation, Piping Layout, especially discharge pipe & sleeves, included pipe connection to BMA area.

**A:** The plan layout section for the civil foundation is not available. The contractor should include the design and the foundation in their proposal, as specified in the Scope of Work. Photographs and information with details for the existing pump may be requested, please contact Khun Poonnakrit Pinla-Or, email: [Pinlaorp@state.gov](mailto:Pinlaorp@state.gov)

**Q2:** Please provide information for the following:

Existing Electrical PI&D, Layout & distance to connect.

**A:** For the system layout and distance to connect, we understand that the connection for the battery charger is about 19 meters, which is to the nearby electrical room. Pictures and AutoCAD file for this solicitation are available by request, please contact Khun Poonnakrit Pinla-Or, email: [Pinlaorp@state.gov](mailto:Pinlaorp@state.gov)

**Q3:** We kindly request to share us the structural design for the station of the pump?

A: Structural design and civil design information and drawings for the pump station and foundation is not available. The contractor should include in the proposal a *new design for the pump station and foundation* as specified in the solicitation documents.

**Q:4** The bid submission due date is extended from May 25, 2022 to June 1, 2022. Bids must be received before 16:00 hrs on June 1. Late bids will not be considered.

Sincerely,

*Scott Krushinski*

Scott Krushinski